

## Ventilation

Facility	Area	Finding	Location	Date
AMKC	1 Top	dirty ceiling vent(s)	janitor's closet	24-Jun
		dirty ceiling vent(s)		28-May
	4 Upper	dirty ceiling vent(s)	showers	28-May
		dirty ceiling vent(s)	toilet area	28-May
		partially/occluded vent	janitor's closet	20-Jul
		partially/occluded vent		28-May
	Main Intake	dirty ceiling vent(s)	janitor's closet	5-May
		dusty ceiling vent(s)	pen #3	16-Jul
		dusty ceiling vent(s)	pen #4	16-Jul
		no vent	pen #6	30-Jul
		no vent	pen #7	30-Jul
		partially/occluded ceiling vent(s)	janitor's closet	13-May
		partially/occluded ceiling vent(s)		19-May
		partially/occluded ceiling vent(s)		9-Jun
		partially/occluded ceiling vent(s)	pen #2	2-Jul
		partially/occluded ceiling vent(s)		9-Jul
	Mod 9B	dirty vent(s)	sleeping area	19-May
		dusty wall vent(s)	sleeping area	17-Jul
	Q13L	dirty vent(s)	cell #30 (vacant)	4-May
		dirty vent(s)	cell #31 (vacant)	8-Jun
	W 17LA	dirty ceiling vent(s)	dayroom	26-May
		partially/occluded ceiling vent(s)	dayroom	22-Jun
		partially/occluded ceiling vent(s)	showers	22-Jun
		partially/occluded ceiling vent(s)	toilet area	22-Jun
	W 17UA	dirty ceiling vent(s)	dayroom	26-May
		dusty ceiling vent(s)	dayroom	24-Jul
		dusty ceiling vent(s)	toilet area	22-Jun
		dusty vent(s)	showers	24-Jul
		partially/occluded ceiling vent(s)	dayroom	26-May
		partially/occluded ceiling vent(s)	showers	22-Jun
		partially/occluded ceiling vent(s)	sleeping area	22-Jun
	Mod 1UA	partially/occluded ceiling vent(s)	cell #5 (occupied)	22-Jul
		partially/occluded ceiling vent(s)	common area	22-Jul
		partially/occluded wall vent(s)	cell #7 (occupied)	22-Jul
GRVC	11B	dirty wall vent(s)	cell #20 (occupied)	11-May
		dirty wall vent(s)	cell #28 (vacant)	11-May
		dirty wall vent(s)	janitor's closet	11-May
		dirty wall vent(s)	showers	11-May
		dust laden vent	cell #30 (occupied)	20-Jul
		no vent	showers	20-Jul
		partially/occluded vent	cell #30 (occupied)	20-Jul
		partially/occluded wall vent(s)	cell #26 (vacant)	20-Jul
		partially/occluded wall vent(s)	janitor's closet	20-Jul
		partially/occluded wall vent(s)	showers	20-Jul
	4B	dirty ceiling vent(s)	showers	8-May
		dirty high wall vent(s)	common area	8-May

## Ventilation

Facility	Area	Finding	Location	Date
		vent(s) "covered with paper"	cell #15 (vacant)	8-May
	7A	dirty high wall vent(s)	common area	10-Jun
		dirty high wall vent(s)		5-May
		dirty wall vent(s)	cell #25 (occupied)	5-May
	8A	partially/occluded (partially) wall vent(s)	cell #31 (vacant)	8-May
		partially/occluded wall vent(s)	cell #25 (occupied)	13-Jul
		partially/occluded wall vent(s)	cell #8 (vacant)	13-Jul
	9B	dirty high wall vent(s)	common area	10-Jun
		dirty high wall vent(s)		5-May
		dirty wall vent(s)	cell #17 (occupied)	10-Jun
		dirty wall vent(s)	cell #29 (vacant)	5-May
		dust laden high wall vents	common area	6-Jul
		partially/occluded ceiling vent	showers	6-Jul
	Intake	dirty ceiling vent(s)	body scan/search area	13-May
		dirty ceiling vent(s)	pen #10	13-May
		dirty ceiling vent(s)		6-May
		dirty ceiling vent(s)	pen #11	18-May
		dirty ceiling vent(s)		8-Jun
		dirty ceiling vent(s)	pen #2	18-May
		dirty ceiling vent(s)		6-May
		dirty ceiling vent(s)		8-Jun
		dirty ceiling vent(s)	pen #3	13-May
		dirty ceiling vent(s)		22-Jun
		dirty ceiling vent(s)		8-Jun
		dirty ceiling vent(s)	pen #5	6-May
		dirty ceiling vent(s)	pen #6	13-May
		dirty ceiling vent(s)		6-May
		dirty ceiling vent(s)		8-Jun
		dirty ceiling vent(s)	pen #8	18-May
		dirty ceiling vent(s)	pen #9	18-May
		partially/occluded ceiling vent(s)	body scan area	1-Jul
		partially/occluded ceiling vent(s)	pen #9	7-Jul
		partially/occluded ceiling vent(s)	scanning area	14-Jul
		partially/occluded ceiling vent(s)		21-Jul
		partially/occluded ceiling vent(s)		29-Jul
		partially/occluded ceiling vent(s)		7-Jul
		partially/occluded ceiling vent(s)	search	14-Jul
		partially/occluded ceiling vent(s)		1-Jul
		partially/occluded ceiling vent(s)		21-Jul
		partially/occluded ceiling vent(s)		29-Jul
		partially/occluded ceiling vent(s)		7-Jul
MDC	5 West	dirty ceiling vent(s)	showers	23-Jun
		dirty wall vent(s)	common area	27-May
		dusty vent(s)	janitor's closet	29-Jul
		partially/occluded vent	showers	27-May
		partially/occluded vent(s)	showers	29-Jul

## Ventilation

Facility	Area	Finding	Location	Date
	Intake	"dried tissue papers" on vent	pen #4	25-Jun
		dirty ceiling vent(s)	search	7-May
		dirty ceiling vent(s)	showers	21-May
		dirty ceiling vent(s)		7-May
		dirty ceiling vent(s)	storage	21-May
		dirty ceiling vent(s)		7-May
		dirty vent(s)	pen #7	21-May
		dirty vent(s)	pen #8	21-May
		dirty vent(s)	search	21-May
		obstructed vent (tissue paper)	pen #8	21-May
NIC	2C	dirty vent(s)	cell #5 (occupied)	25-Jun
		dirty vent(s)	cell #6 (vacant)	25-Jun
		no vent	storage	25-Jun
		partially/occluded vent	cell #4 (vacant)	25-Jun
OBCC	3 Lower	dirty ceiling vent(s)	showers	14-Jul
		dirty ceiling vent(s)	toilet area	14-Jul
		dirty vent(s)	sleeping area	13-May
	3 North	dirty vent(s)	cell #12 (vacant)	5-May
		dirty vent(s)	cell #27 (vacant)	8-Jul
		dirty vent(s)	cell #8 (vacant)	10-Jun
	5 West	dirty ceiling vent(s)	3 point search	8-Jul
		dirty ceiling vent(s)	showers	8-Jul
		dirty vent(s)	cell #17 (vacant)	5-May
		dirty vent(s)	cell #30 (vacant)	10-Jun
		dirty vent(s)	cell #42 (vacant)	8-Jul
		dirty vent(s)	cell #47 (vacant)	5-May
	7 Lower	dirty ceiling vent(s)	dayroom	14-Jul
		dirty ceiling vent(s)	showers	14-Jul
		dusty vent(s)	dayroom	13-May
	Main Intake	partially/occluded ceiling vent(s)	pen #14	10-Jul
RMSC	Bldg. 1	dirty wall vent(s)	cell #6 (vacant)	4-May
		dusty high ceiling vent(s)	common area	4-May
	Bldg. 2	dusty high ceiling vent(s)	common area	4-May
		dusty high wall vent(s)	common area	4-May
		dusty vent(s)	cell #6 (vacant)	13-Jul
		paint on vent(s)	cell #12 (vacant)	4-May
		paint on vent(s)	cell #7 (vacant)	4-May
	Intake	dirty ceiling vent(s)	search	12-Jun
		dirty vent(s)	showers	31-Jul
		dusty ceiling vent(s)	search	22-Jun
RNDC	5 Lower S	dirty vent(s)	cell #10 (vacant)	7-May
		dirty vent(s)	janitor's closet	23-Jun
	6 Upper S	"vent noted painted"	cell #3 (vacant)	12-May
		dusty vent(s)	showers	12-May
		partially/occluded vent	cell #3 (vacant)	13-Jul
		partially/occluded vent	cell #5 (vacant)	13-Jul

## Ventilation

Facility	Area	Finding	Location	Date
		partially/occluded vent	showers	13-Jul
		vent "clogged with paint"	cell #5 (vacant)	12-May
VCBC	3CB	dirty ceiling vent(s)	common area	20-May
		dirty ceiling vent(s)	janitor's closet	20-May
		dirty ceiling vent(s)	showers	20-May
		dirty high wall vent(s)	common area	23-Jun
		dirty wall vent(s)	cell #2L (vacant)	23-Jun
		dirty wall vent(s)	cell #L1 (vacant)	20-May
		dirty wall vent(s)	cell #L3 (occupied)	20-May
		dusty vent(s)	common area	30-Jul
		partially/clogged vent(s)	cell #24L (vacant)	30-Jul
		partially/occluded vent	cell #5U (occupied)	23-Jun
	Intake	dirty ceiling vent(s)	common area	12-Jun
		dirty ceiling vent(s)		20-May
		dirty ceiling vent(s)		29-May
		dirty ceiling vent(s)		7-May
		dirty ceiling vent(s)	janitor's closet	12-Jun
		dirty ceiling vent(s)		20-May
		dirty ceiling vent(s)		29-May
		dirty ceiling vent(s)		7-May
		dirty ceiling vent(s)	pen #11	12-Jun
		dirty ceiling vent(s)		20-May
		dirty ceiling vent(s)	pen #12	12-Jun
		dirty ceiling vent(s)		7-May
		dirty ceiling vent(s)	pen #14	12-Jun
		dirty ceiling vent(s)		20-May
		dirty ceiling vent(s)	pen #3	20-May
		dirty ceiling vent(s)	pen #4	20-May
		dirty ceiling vent(s)		29-May
		dirty ceiling vent(s)	pen #5	29-May
		dirty ceiling vent(s)		7-May
		dirty ceiling vent(s)	pen #6	29-May
		dirty ceiling vent(s)		7-May
		dirty ceiling vent(s)	pen #7	29-May
		dirty ceiling vent(s)	pen #8	7-May
		dirty ceiling vent(s)	toilet area	12-Jun
		dirty ceiling vent(s)		20-May
		dirty ceiling vent(s)		29-May
		dirty ceiling vent(s)		7-May
		dusty ceiling vent(s)	janitor's closet	25-Jun
		dusty vent(s)	common area	16-Jul
		dusty vent(s)		30-Jul
		dusty vent(s)		9-Jul
		dusty vent(s)	pen #2	30-Jul
		dusty vent(s)	pen #9	9-Jul
		partially/occluded ceiling vent(s)	common area	25-Jun

## Ventilation

Facility	Area	Finding	Location	Date
		partially/occluded vent	showers	25-Jun
	2BA	dusty vent(s)	sleeping area	16-Jul
West Facility	CDU Intake (Sp. 5)	dusty ceiling vent(s)	pen #8	24-Jun
	Main Intake	dust laden ceiling vent	showers	31-Jul
		no vent	janitor's closet	24-Jul
		no vent		31-Jul
		no vent	pen #3	24-Jul
		no vent		31-Jul
		partially/occluded ceiling vent(s)	common area	24-Jul
		partially/occluded ceiling vent(s)		31-Jul